

Site Visit Report



100 Grove Street
Worcester, MA 01605
T 508-856-0321
F 508-856-0357
gravesengineering.com

Date: January 9, 2024
Client: Sutton Planning Board
Project: 15 Pleasant Valley Road
Contractor: Coastal Construction Corp.
Contractor Contact: Rian Kearney

Prepared By: Jeffrey Walsh
Arrived on site: 1:35 PM
Left site: 2:00 PM
Site Conditions: Wet, Snow Cover
Weather: 35°, Cloudy

Transmitted by:

<input checked="" type="checkbox"/> Mail	<input checked="" type="checkbox"/> E-mail
<input type="checkbox"/> Hand	<input type="checkbox"/> Other:
<input type="checkbox"/> Fax	

Comments:

Graves Engineering, Inc. (GEI) was on-site to observe excavation for the subsurface infiltration system. This site visit was conducted throughout the entire site. I met with Steve ____ of Anchor Excavating Corporation, Jack Guilford of Coastal Construction Corporation and Greg DiBona of Bohler. We observed the following:

- The location of the subsurface infiltration system had been excavated to a width of ± 30 feet and a length of ± 90 feet. The bottom of the excavated area was comprised of suitable, native gravelly sand.
- The bottom of the excavated area had been scarified in a satisfactory manner.
- The contractor was installing the frame of the building during my site visit.

Based upon visual observations only, the work observed today appeared to be consistent with the approved plans.

Action to be Taken:

Client will be notified of this site visit by way of this report.

Copies:

cc: Rian Kearney; Coastal Construction Corporation
Pete Doucet; Torrington Properties

Photos:

The following photos were taken during today's site visit.



Photo 1: The bottom of the excavated area for the subsurface infiltration system had been scarified in a satisfactory manner.



Photo 2: The contractor was installing the frame of the building.