

From: [Lindsey](#)
To: [Jennifer Hager](#)
Cc: [Tammy Mahoney](#)
Subject: Re: 435 BOSTON ROAD - SUTTON - S22-03 - PLAN REVIEW
Date: Tuesday, December 20, 2022 7:58:43 PM
Attachments: [Easement Sketch \(431 Boston Rd\).pdf](#)
[Untitled attachment 00271.htm](#)

Hi Tammy,

Attached is the drawing from national grid for the planning board meeting next week. Also, the text below from the engineer is to support the drawing . Can you let me know what else you need from me to get into the meeting on the 27th? Thank you!

Also, I would assume that this email would serve as an acceptable form of communication from National Grid that the rough preliminary plan to serve your property, as of now, is as follows:

To run single-phase underground primary from existing pole # 51 (P#51 to be replaced for reliability) along side new driveway, rise up primary on new poleline outside of wetlands, and end with an Overhead transformer on last pole on other side of stream. Secondary to be trenched from last pole on poleline to a meter socket mounted on house. All distances and exact number of pole to be determined by Easement Sketch and finalized measured distances in-field by National Grid Field Engineer.

Let me know if you have any further questions for me.

Thank you,

Rob Greene

Distribution Design-Designer B

939 Southbridge St.

Worcester, MA 01610

Work Cell: (508) 353-4951

robert.greene@nationalgrid.com