Site Visit Report



100 Grove Street Worcester, MA 01605 T 508-856-0321 F 508-856-0357 gravesengineering.com

Date:June 23, 2023Client:Sutton Planning BoardProject:Unified ParkwayContractor:Walsh Contracting Corp.

Contractor Contact: John Walsh

Prepared By: Olivia Caton
Arrived on site: 11:20 AM
Left site: 11:45 AM
Site Conditions: Dry

Weather: 74°, Partly Cloudy

Transmitted by:			
\boxtimes	Mail		
	Hand	☐ Other:	
	Fax		

Comments:

Graves Engineering, Inc. (GEI) was on-site to observe construction of the road and the road's drainage/stormwater management system. This site visit was conducted throughout the entire site. I observed the following:

- Stormwater Management Area (SWMA) #1 was experiencing approximately 75% grass growth.
- SWMA #2 was experiencing approximately 50% grass growth. The northern third of the area needs to be reseeded to encourage additional grass growth.
- SWMA #3 was experiencing approximately 50% grass growth along the northern, eastern, and western slopes, and 20% in the southeastern corner. The southwestern corner and bottom showed no signs of grass growth. The area needs to be reseeded to encourage additional grass growth.
- The slope between stations 43+00 and 45+00 was experiencing approximately 70% grass growth.
- SWMAs #1 and #2 were dry. SWMA #3 was damp.

Based upon visual observations only, the work observed today appeared to be consistent with the approved plans.

Action to be Taken:

Client will be notified of this site visit by way of this report.

Copies:

cc: John Walsh; Walsh Contracting Corp.
Matthew Piekarski; The Kraft Group, LLC

Photos:

The following photos were taken during today's site visit.



Photo 1: SWMA #1 was experiencing approximately 75% grass growth.



Photo 2: SWMA #3 was experiencing approximately 50% grass growth along the slopes, and no grass growth on the bottom.