

From: [Don Provencher](#)
To: ["Piekarski, Matt"](#); ["Jennifer Hager"](#)
Cc: ["John Kucich \(Bohler\)"](#); ["Keith Curran"](#); ["Andrew Steiner"](#); ["Shelly Gorman \(WWD\)"](#); JWalsh@gravesengineering.com
Subject: RE: FW: Geo-Storage // Unified2 // Sutton, MA // Graves Comments
Date: Monday, February 13, 2023 10:05:24 AM

Hi Matt & Jen:

I reviewed the new stormwater recharge system and I don't believe the proposed changes would be expected to have any different impacts on the Hatchery Road well any different than the initial design. The proponent is still infiltrating runoff consistently with the previous volumes and location.

Thanks, Don

Donald A. Provencher, P.E.
Provencher Engineering, LLC
6 Wasserman Heights
Merrimack, NH 03054
Phone/Fax (603) 883-4444
Don@Provencher.com
ProvencherEngineering.com



Please consider the environment before printing this email

From: Piekarski, Matt [mailto:MattP@thekraftgroup.com]
Sent: Friday, February 10, 2023 9:28 AM
To: Shelly Gorman (WWD) <wilkswater@verizon.net>; Don Provencher (Provencher Eng) <don@provencher.com>
Cc: John Kucich (Bohler) <jkucich@bohlereng.com>; Keith Curran <kcurran@bohlereng.com>; Andrew Steiner <asteiner@bohlereng.com>
Subject: FW: FW: Geo-Storage // Unified2 // Sutton, MA // Graves Comments

Shelly, as Jen indicated below, we are submitting the attached email and link below for a submission regarding the sub-surface stormwater recharge system.

The concept and approach are the same as was reviewed and approved, it's just a different proprietary system.

If you can please review and comment as requested by Jen it would be appreciated.

Any specific comment or questions can be directed to Bohler as needed (copied here).

Thank you,
Matt

From: Piekarski, Matt

Sent: Friday, February 10, 2023 9:23 AM

To: 'Jennifer Hager' <j.hager@town.sutton.ma.us>; John Kucich <jkucich@bohlereng.com>;
Wilkinsonville Water District <wilkswater@verizon.net>

Cc: Keith Curran <kcurran@bohlereng.com>; w211141@nf.bohlereng.com; Jeffrey Walsh
<JWalsh@gravesengineering.com>; Andrew Steiner <asteiner@bohlereng.com>

Subject: RE: FW: Geo-Storage // Unified2 // Sutton, MA // Graves Comments

Thanks Jen.

We will coordinate with the WWD on this.

Matt

From: Jennifer Hager <j.hager@town.sutton.ma.us>

Sent: Thursday, February 9, 2023 7:35 PM

To: John Kucich <jkucich@bohlereng.com>; Wilkinsonville Water District <wilkswater@verizon.net>

Cc: Piekarski, Matt <MattP@thekraftgroup.com>; Keith Curran <kcurran@bohlereng.com>;
w211141@nf.bohlereng.com; Jeffrey Walsh <JWalsh@gravesengineering.com>; Andrew Steiner
<asteiner@bohlereng.com>

Subject: Re: FW: Geo-Storage // Unified2 // Sutton, MA // Graves Comments

Hi John: If Jeff's good the Towns good BUT I also would like you to submit this to Wilks water to make sure they are also good before it is approved, likely as a field change. Thanks Jen

Jennifer Hager,
Sutton Planning &
Economic Development Director
508-865-8729

On Thu, Feb 9, 2023, 2:16 PM John Kucich <jkucich@bohlereng.com> wrote:

Hello Jen. The contractor is proposing an alternative product for the underground stormwater management areas behind Building #3 (UG3c) and to the south side of Building #2 (UG2e). They are proposing to switch from the previously approved Stormtech MC-3500 and MC-4500 chamber systems to a "Geo-Storage" system. This system is beneficial as it uses the existing blast rock readily available on site. The alternative systems are an equivalent to the previously approved Stormtech chambers. We have reviewed this proposed change with Jeff Walsh (Graves Engineering, Inc.) and they confirmed it meets the standards (see attached email) do not have any issue with this modification. Please find the supporting documentation in the link below. It is our hope that this could be viewed as a simple administrative change. Please reach out if you have any questions, comments or require additional information.

[Download all files](#)

John Kucich, P.E.

Principal

o 508-480-9900 / c 508-341-1837 / jkucich@bohlereng.com



Please be advised that the Attorney General has ruled that communication via electronic mail in the public domain is not confidential and is considered a matter of public record. Furthermore, all communications (including this one) will be retained for 10 years.

NOTICE: This message and any attachments are solely for the intended recipient and may contain confidential or privileged information. If you are not the intended recipient, you are hereby notified that any review, dissemination, distribution or duplication of this message and any attachments is prohibited. If you have received this communication in error, please notify us by reply email and immediately and permanently delete this message and any attachments. Email transmission may not be secure and could contain errors. We accept no liability for any damage caused by any virus transmitted by this email. Please do not send to us by email any information containing personally identifiable information without appropriate encryption. Thank you.