

From: [John Kucich](#)
To: [Jennifer Hager](#)
Cc: [Piekarski, Matt](#)
Subject: RE: loose end . . .
Date: Monday, July 25, 2022 4:14:35 PM
Attachments: [image001.png](#)

Correct, we are not in excess of the 10% and 3% requirements. We comply.

Thanks,
John

John Kucich, P.E.

Principal

o 508-480-9900 / c 508-341-1837 / jkucich@bohlereng.com

BOHLER //

From: Jennifer Hager <j.hager@town.sutton.ma.us>
Sent: Monday, July 25, 2022 4:06 PM
To: John Kucich <jkucich@bohlereng.com>; Piekarski, Matt <MattP@thekraftgroup.com>
Subject: loose end . . .

EXTERNAL: Use caution with attachments and links.

Please confirm the grade of the common driveway for compliance with this provision. I checked you 6/8/22 response to comments and it was not addressed.

4. Maximum grade of ten percent (10%), three percent (3%) within 50 feet of the street line.

Jennifer S. Hager

Planning & Economic Development Director

Town of Sutton

4 Uxbridge Road

Sutton, MA 01590

(508) 865-8729

j.hager@town.sutton.ma.us

Please be advised that the Attorney General has ruled that communication via electronic mail in the public domain is not confidential and is considered a matter of public record. Furthermore, all communications (including this one) will be retained for 10 years.